

Tuberculosis Demonstration & Training Centre Agamkuan, Patna- 800007

Minutes of Pre Bid Meeting: 3rd March 2012

741 AD
13/09/12

12

12

5th May 2011

12.3

3. Query regarding height of walk in Cooler Page-8, 1/a

Concern were expressed on dimension (external size) of cold room i.e. 2.65 m x 2.65 m x 3.61 m (height)

Clarification:

The room for equipment was selected, after the physical verification, on joint visit by C.T.D., W.H.O. and N.R.L. team and it was not possible to comment or suggest any deviation from the technical specifications, without discussion with supporting National Reference Laboratory/CTD.

4. Query regarding submission of non conviction certificate (3..4.6) and " that the company has not been blacklisted/ de-registered / barred "

It was asked whether the separate affidavits sworn before First Class Magistrate are required for non conviction certificate (3.4.6) and " that the company has not been blacklisted/ de-registered / barred " (3.4.7)?

Clarification:

It was reiterated that both certificates are essential.

5. Query regarding specifications of "Walk in Incubator"

It was highlighted that the specification for various components of "Walk in Incubator" not elaborated in the tender document.

Clarification:

The specifications for WIC and Walk in Incubator were recommended by NTI after the joint visit (19.05.2010) by CTD, WHO and NRL team and the suppliers having customer satisfaction, from 25 or more for similar works will only be selected.

6. Query regarding range of acceptable fluctuation in temperature

It was said that the temperature inside equipment does not remain constant and the fluctuation what could be acceptable need to mentioned

Clarification:

No comment.

However need of data logger, for WIC & Walk in incubator, may be considered after discussion with NRL.

7. Query regarding material of racks- whether S.S. or M.S. for WIC/Incubator

Clarification:

Rust proof material.


8. Suggestion for back up compressor with auto switch over Walk In Cooler

Clarification:

Considering the unforeseen breakdown of a compressor, the suggestion for back up compressor with auto switch appears reasonable however no comment could be made without the further discussion with NRL.


9. Query regarding refund of performance security:

12



Clarification:


70% payment would be made after the certification of installation & functional status of the equipments by Microbiologist, National Tuberculosis Institute, Bengaluru /Central TB Division, remaining 30% would be paid as specified on page 5/2.21.1



Dr. Amar Nath Jha
Director, TBDC, Patna


Memo No. 168 PATNA/ Dated: 03.03.2012

C. C.

- ✓ 1. Administrative Officer, State Health Society, Bihar for information with request to upload on website of State Health Society, Bihar.
2. Dy. Director, Finance, State Health Society, Bihar for his for his information and necessary action.
3. Dy. Director (Health) cum State Programme Officer-TB, Bihar, Bihar for his information.
4. Dr. K. S. Sachdeva, C.M.O-TB, Central TB Division, MoHFW, Nirman Bhawan, for his information and necessary action.
5. Director, National Tuberculosis Institute, Bengaluru for his information further guidance.
6. Director in Chief, Health Services, Bihar, for his information.
7. Secretary (Health) cum Executive Director, State Health Society, Bihar for his information and necessary action.
8. Principal Secretary (Health), Bihar government for kind information please


Dr. Amar Nath Jha
Director, TBDC, Patna


3.3.12
चिकित्सा पदाधिकारी
यहमा प्रदर्शन एवं प्रशिक्षण केन्द्र
अगमकुश, पटना-7


03/03/12